

BATCH REPORT



COMPANY:	ABC COMPANY
YOUR INTEC REP:	Dale Roark 801 - 357 - 9644

DATE: 3/7/12
 BATCH #: 35119
 SEE INVOICE #: 35119
 CUSTOMER SINCE: 8/5/10
 CUSTOMER PO: 5689

"Air Filter Cleaning You Can Trust"

FILTER PART #	FILTER MAKE	BAR CODE	CFM RATING	TIMES CLEANED	% OF NEW	PASS FAIL	VISUAL INSPECTION	REASON FOR FAILURE	WEIGHT DIRTY	WEIGHT CLEAN	LBS. REMOVED	CUSTOMER COST	INTEC PRICE	CUSTOMER SAVINGS
50	DOLLINGER	B4933F8B	FS	8	95.7%	P	√		6.8	6.4	0.4	\$184.71	\$101.59	\$83.12
50	DOLLINGER	608DD9B0	FS	4	97.5%	P	√		6.8	6.6	0.2	\$184.71	\$101.59	\$83.12
50	DOLLINGER	F3BD7D51	FS	4	98.9%	P	√		6.8	6.4	0.4	\$184.71	\$101.59	\$83.12
50	DOLLINGER	E4C9BB73	FS	8	96.3%	P	√		6.8	6.4	0.4	\$184.71	\$101.59	\$83.12
50	DOLLINGER	BB8205A1	FS	2	99.8%	P	√		7.5	7.1	0.4	\$184.71	\$101.59	\$83.12
51	DOLLINGER	FD08DFE4	FS	3	FS	P	√		19.7	19.3	0.4	\$768.91	\$422.90	\$346.01
51	DOLLINGER	F19D5B0D	FS	3	FS	P	√		20.6	19.6	1.0	\$768.91	\$422.90	\$346.01
35016	DOLLINGER	9568B626	FS	12	99.8	P	X	Bent Cage	12.1	11.5	0.6			
35016	DOLLINGER	678A4F23	FS	12	99.7	P	√		12.2	11.6	0.6	\$400.00	\$220.00	\$180.00
46470	CAT/WIX	70E51E5C	1730	4	98.4	P	√		11.2	6.7	4.5	\$140.00	\$77.00	\$63.00
46470	CAT/WIX	4289D386	1730	6	97.5	P	√		10.5	6.8	3.7	\$140.00	\$77.00	\$63.00
46470	CAT/WIX	673FB0A1	1730	3	98.70%	P	√		10.8	6.7	4.1	\$140.00	\$77.00	\$63.00
6I-2509	CAT/WIX	172145FD	1025	3	99.10%	P	√		10.0	8.7	1.3	\$91.00	\$50.05	\$40.95
6I-2509	CAT/WIX	9FF2144D	1025	2	99.40%	P	√		9.4	8.4	1.0	\$91.00	\$50.05	\$40.95

LEGEND: FS = Factory Spec not published. NF = New filter required to establish baseline.	LBS. OF DIRT REMOVED THIS BATCH:	19.0	BATCH SAVINGS:	\$1,558.52
	TOTAL LBS. OF DIRT REMOVED:	1,369.8	TOTAL SAVINGS:	\$135,521.51